

# CERTIFICATE OF COMPLIANCE

**Certificate Number** E228634  
**Report Reference** E228634-2015-12-19  
**Date** 2023-January-13

**Issued to:** DOUGLAS ELECTRICAL COMPONENTS INC  
5 Middlebury Blvd  
Randolph NJ, 07869-1112 US

**This is to certify that  
representative samples of**

PREFABRICATED WIRING ASSEMBLIES FOR USE IN  
HAZARDOUS LOCATIONS

See Addendum Page for Product Designation(s).

Have been evaluated by UL in accordance with the  
Standard(s) indicated on this Certificate.

**Standard(s) for Safety:**

UL 1203, Explosion-Proof and Dust-Ignition-Proof Electrical  
Equipment for Use in Hazardous (Classified) Locations,  
CAN/CSA C22.2 No. 30, Explosion-proof equipment.

**Additional Information:**

See the UL Online Certifications Directory at  
<https://iq.ulprospector.com> for additional information

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.

*Deborah Jennings-Conner*

Deborah Jennings-Conner, VP Regulatory Services

UL LLC



Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

# CERTIFICATE OF COMPLIANCE

**Certificate Number** E228634  
**Report Reference** E228634-2015-12-19  
**Date** 2023-January-13

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

**Product Designation(s):**

USL, CNL - Hubs, Cat. Nos. 52240 and 52540, trade size 1/2, 3/4, and 1 in., for use in Class I, Division 1, Groups A, B, C and D Hazardous Locations.

Hubs, Cat. Nos. 52539, trade size 1/2 and 3/4 in., for use in Class I, Division 1, Groups B, C and D Hazardous Locations.

Hubs, Cat. Nos. 52240 and 52539, trade size 1/2 and 1 in., for use in Class I, Division 1, Groups C and D Hazardous Locations.



*Deborah Jennings-Conner*  
Deborah Jennings-Conner, VP Regulatory Services

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>